

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60136

1. OWNER B & B INVESTMENTS ADDRESS AT WELL LOCATION None established  
 MAILING ADDRESS 555 PINE ST. ELKO, NV 89801 2942 Hemmingbird St.  
 2. LOCATION NE 1/4 SW 1/4 Sec 15 T 32 N 8 R 55 E County \_\_\_\_\_  
 PERMIT NO. N/A Issued by Water Resources | 027-01A-005 Parcel No. | ELKO Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sandy soil</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Gravel &amp; boulders</u>		<u>3</u>	<u>15</u>	<u>12</u>
<u>Brown Clay</u>		<u>15</u>	<u>45</u>	<u>30</u>
<u>White Clay</u>		<u>45</u>	<u>70</u>	<u>25</u>
<u>Brown clay</u>		<u>70</u>	<u>78</u>	<u>8</u>
<u>Gravel</u>	<u>199m</u>	<u>78</u>	<u>80</u>	<u>2</u>
<u>Brown sandy clay</u>		<u>80</u>	<u>125</u>	<u>35</u>
<u>Gravel (total 89m)</u>	<input checked="" type="checkbox"/>	<u>125</u>	<u>130</u>	<u>5</u>
<u>Sandy clay</u>		<u>130</u>	<u>160</u>	<u>30</u>
<u>Clay w/sand streaks</u>	<input checked="" type="checkbox"/>	<u>160</u>	<u>175</u>	<u>15</u>
<u>Clay</u>		<u>175</u>	<u>180</u>	<u>5</u>
<u>G.P.S.</u>				
<u>115.76995 W</u>		<u>40.658°N</u>	<u>NAD 27</u>	
<u>40.65745 N</u>		<u>115.769°W</u>		

8. WELL CONSTRUCTION 180  
 Depth Drilled 180 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 51 Feet  
8 Inches 51 Feet 130 Feet  
6 Inches 130 Feet 180 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>1.88</u>	<u>±1 1/2</u>	<u>180</u>

 Perforations:  
 Type perforation Touch out  
 Size perforation 1/8 x 4  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 110 feet to 130 feet  
 From 160 feet to 175 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 180 feet

Date started 4/30, 2009  
 Date completed 5/13, 2009

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
<input checked="" type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift	
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>1621</u>	<u>6.46</u>	<u>11:00</u>	<u>600hr</u>

9. WATER LEVEL  
 Static water level 78 feet below land surface  
 Artesian flow No G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature cold °F Quality good  
 10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name M.U.V.N. DRILLING CO Contractor  
 Address 203 Pine St, Elko, NV 89801 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 10819  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 633  
 Signed James V. White  
 By driller performing actual drilling on site or contractor  
 Date 5-20-09