

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64458

1. OWNER B. & B. INVESTMENTS ADDRESS AT WELL LOCATION Not established  
 MAILING ADDRESS 355 PINE ST. ELKO, NV 89801 2954 Hummingbird St.  
 2. LOCATION NE 1/4 SW 1/4 Sec. 15 T. 32 N. R. 5. E ELKO County \_\_\_\_\_  
 PERMIT NO. N/A Issued by Water Resources | 027-019-004 Parcel No. | LUCKY NUGGET RANCHES Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy soil		0	3	3
Sand, gravel, boulders		3	17	14
Brown, sandy clay		17	60	43
White clay		60	82	22
Loose gravel	seep	82	84	2
Brown sandy clay		84	154	70
Clay, sand, gravel	✓	154	156	
White clay		156	159	3
Clay & gravel	✓✓	159	162	3
Clay		162	168	6
G.P.S. 115.76997W. 40.65687N.				
<del>40.65687N. 115.76997W.</del>				

8. WELL CONSTRUCTION 168  
 Depth Drilled 168 Feet Depth Cased 168 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
1.0 Inches 0 Feet 50 Feet  
8 Inches 50 Feet 168 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>0.183</u>	<u>1 1/2</u>	<u>10</u>
<u>6 7/8</u>	<u>14.80</u>	<u>0.17</u>	<u>10</u>	<u>168</u>

Perforations:  
 Type perforation Factory Screen PVC  
 Size perforation \_\_\_\_\_  
 From 13.5 feet to 15.5 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 168 feet

9. WATER LEVEL  
 Static water level 82 feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MUTH DRILLING Co. Contractor  
 Address 203 Pine St., ELKO, NV 89801 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 10819  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632  
 Signed James Y. Muth  
 By driller performing actual drilling on site or contractor  
 Date 6-02-09

Date started 5-18, 2009  
 Date completed 6-4, 2009

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>178</u>	<u>01:17:21</u>
G.P.M.		