WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110222
Permit No.
Basin 140A

NOTICE OF INTENT NO. 63617 (i)

1. OWNER Donna Whitteman
MAILING ADDRESS 835 San Gabriel Ave Henderson NV 89002
ADDRESS AT WELL LOCATION 3 miles west on Stanceberger Road from monitor Valley

2. LOCATION 5E ¼ 5W ¼ Sec. 13 T. 15 N/S R. 46 E. NYE County
PERMIT NO. Issued by Water Resources | 05-571-02 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	18	18
Sand-Boulders		18	90	72
Fractured Rock	X	90	110	20
Hard Rock		110	114	4

WGS 84
N 39° 07.937'
W 116° 44.626'

39.132,361°N NAD27 DD
116.742,851°W

Date started 3-7-09, 20
Date completed 3-12-09, 20

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2	60	2

RECEIVED
2009 APR 6 PM 1:10
STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
Depth Drilled 114 Feet Depth Cased 114 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
11	0	114

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	PVC	SCH 40	0	114

Perforations:
Type perforation Sawcut
Size perforation 1/8" x 31
From 104 feet to 114 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 104 feet to 114 feet

9. WATER LEVEL
Static water level 42 feet below land surface
Artesian flow 0 G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko NV 89017 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed (By driller performing actual drilling on site or contractor)
Date 3-20-09

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY MMH - (F) (O)-627