

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63629 ①

1. OWNER Kerth Kubick K ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4062 W. Winnemucca Blvd Diesel Drive
Winnemucca NV 89445 Winnemucca NV.
 2. LOCATION SW 1/4 NW 1/4 Sec 1 T 35 S/R 37 E Humboldt County
 PERMIT NO. 013-022-13 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand	NO	0	5	5
Clay	NO	5	10	5
Sand & gravel	NO	10	45	35
cemented rocks	NO	45	80	35
Sand & gravel	Yes	80	130	50
Clay	Yes	130	135	5
Sand & gravel	Yes	135	145	10
Clay	Yes	145	150	5

N 40° 56' 36" E
 W 117° 46' 29" E
 NAD 27

40.939, 350° N NAD 27 D.D.
 117.771, 633° W

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/8 Inches To 150 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>Steel</u>	<u>.188</u>	<u>0</u>	<u>10</u>
<u>6 5/8</u>	<u>PVC</u>	<u>Sched 40</u>	<u>10</u>	<u>150</u>

Perforations:
 Type perforation Hand cut slot
 Size perforation .125
 From 100 feet to 150 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 150 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality clear

Date started 04-1, 2009
 Date completed 4-7, 2009

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>NA</u>	<u>7</u>

RECEIVED
 APR 30 AM 11:38
 STATE ENGINEER

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Firstgold Corp. Contractor
 Address P.O. Box 6 Lovelock NV, 89419 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0071020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 067
 Signed Frank Moore
 By driller performing actual drilling on site or contractor
 Date 4-27-09