

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33744 (1)

1. OWNER Bradley Walsh ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO Box 232 East of Wadsworth Ranch
NE Alamo, NV 89001
 2. LOCATION NE 1/4 SW 1/4 Sec. 14 T. 3 N 57 E Nye County
 PERMIT NO. 013-821-20 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	55	55
Clay, silt, sand		55	70	15
Clay		70	80	10
Clay, Gravel		80	120	40
Purple Granite	✓	120	340	220
White Quartz	✓	340	420	80

REC'D
 2009 MAY 20 AM 10:55
 STATE ENGINEER'S OFFICE
 N38° 07.377'
 W 115° 32.514'
 JAN 83
 38.123, 004°N NAD27 D.D.
 115.541, 037°W

8. WELL CONSTRUCTION
 Depth Drilled 420 Feet Depth Cased 420 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 4 1/2 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	17.02	.250	+ 18"	420

 Perforations:
 Type perforation Mill
 Size perforation 1/8"
 From 300 feet to 420 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 420 feet

9. WATER LEVEL
 Static water level 180 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Gardner Brothers Drilling Contractor
 Address P.O. Box 965 Contractor
Enterprise, UT 84725
 Nevada contractor's license number issued by the State Contractor's Board DD68459
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1710
 Signed Dale Gardner
 By driller performing actual drilling on site or contractor
 Date 5-18-09

Date started April 20, 2009
 Date completed May 15, 2009

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	<u>20</u>		<u>2 1/2 Hours</u>