

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 110572  
Permit No. \_\_\_\_\_  
Basin φ91

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60985

1. OWNER Cheryl and Harold Hall  
MAILING ADDRESS 2384 Red Maple Ct.  
Reno NV 89523

ADDRESS AT WELL LOCATION 517 Crystal Peak Rd  
Verdi, NV  
Subdivision Name: \_\_\_\_\_ County: Washoe

2. LOCATION ne ¼ SE ¼ Sec 18 T 19N N/S R 18 E  
PERMIT/WAIVER No. 038-081-14  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude 39.51144 UTM E  NAD 27  
Longitude 119.99413 N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
boulders		0	25	
rock/clay		25	210	
clay		210	265	
rock		265	295	
39.511, 2.31°N NAD27 O.D.				
119.993, 0.96°W				

9. WELL CONSTRUCTION

Depth Drilled	295	Feet	Depth Cased	295	Feet
HOLE DIAMETER (BIT SIZE)					
	From		To		
10 5/8	Inches	0	Feet	100	Feet
8 3/4	Inches	100	Feet	295	Feet
	Inches		Feet		Feet
CASING SCHEDULE					
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)	
6 5/8	12.97	1.88	+ 1 1/2	295	

Perforations:

Type of perforation factory  
Size of perforation 3/32

From 275 feet to 295 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement 0 to 100  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 100 to 295  Pumped  Poured

Type: \_\_\_\_\_  
Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 9-May 20 08  
Date completed: 21-May 20 08

7. Water Level  
Static water level: 15 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	15	85	30 min
	20	110	1 hr
	30	280	3.5 hrs

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name McKay Drilling, Inc  
Contractor

Address 4850 Joule St. Suite A5  
Contractor

Reno, NV 89502

Nevada contractor's license number issued by the State Contractor's Board 14170

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 786

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date 2/13/2008

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

MMH - (F)