

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110600
Permit No. 179
Basin

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65317

1. OWNER Robinson NV. Mining
MAILING ADDRESS PO Box 382
Ruth, NV. 89319

RP10-05 ADDRESS AT WELL LOCATION Murray Springs, Ely
Subdivision Name: County: White Pine

2. LOCATION NE 1/4 NE 1/4 Sec 29 T16N R63E
PERMIT/WAIVER NO. M/O-1619
Issued by Water Resources Parcel No.

Latitude UTM E 681250 NAD 27
Longitude N 4343958 NAD 83/WGS 84

3. WORK PERFORMED
New Well Replace Recondition
Deepen Other

4. PROPOSED USE
Domestic Irrigation Monitor Test Stock
Municipal/Industrial

5. WELL TYPE
Cable Rotary RVC
Air Other

6. LITHOLOGIC LOG table with columns: Material, Water Strata, From, To, Thickness. Rows include Soil, Alluvium, Fractured Brown Limestone, Grayish Brown Limestone, Grey Clay, Brown Limestone w/clay, Grey Clay, Black Colored Shale, Grey Clay, Black Soft Shale.

9. WELL CONSTRUCTION
Depth Drilled 900 Feet Depth Cased 900 Feet
HOLE DIAMETER (BIT SIZE)
From To
12.75 Inches 0 Feet 111 Feet
6.50 Inches 111 Feet 900 Feet

CASING SCHEDULE table with columns: Size O.D. (Inches), Weight/Ft. (Pounds), Wall Thickness (Inches), From (Feet), To (Feet)

NAD 27 GPS
39.227884° N
114.900241° W
Hole was Abandoned
See Details

Perforations:
Type of perforation
Size of perforation
From feet to feet

Annular Seal: Yes No
Neat Cement 0 to 20 Pumped Poured
Cement Grout to Pumped Poured
Concrete Grout to Pumped Poured
30% Bentonite Grout 20 to 900 Pumped Poured
Gravel Pack: Yes No to Pumped Poured
Type:
Bentonite Chips: Yes No to Pumped Poured
Type:

Date started: February 28, 2010
Date completed: March 4, 2010

7. Water Level
Static water level: 61 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)

8. WELL TEST DATA table with columns: TEST METHOD (Bailer, Pump, Air Lift), G.P.M., Draw Down (Feet Below Static), Time (Hours). Row 1: 280-300, N/A, 3.

Address 2745 California Ave. (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2350
Signed [Signature]
By driller performing actual drilling on site or contractor
Date April 27, 2010

STATE ENGINEER
MAY 05 2010
FACSIMILE COPY

Original received 4/30/2010, returned for correction. (20)-2