REPORT NO. AB10.08

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 110654
PERMIT NO.
BASIN 084

NOTICE OF INTENT NO. 64294

1. OWNER Don Fox
MAILING ADDRESS 5255 Twin Springs Road Reno, NV 89510

ADDRESS OF WELL 5255 Twin Springs Road
Reno, NV 89510

2. WELL LOCATION NE 1/4 SW 1/4 SEC. 30 T 22 R 22 E Washoe COUNTY
PERMIT NO PARCEL NO 177-300-15 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Fractured Rock and Sand		210	230	
Gray Clay and Sands		230	280	
Multi-Colored Rock		280	320	
Gray Clay and Rock		320	520	
Gray Clay		520	530	
Gray Clay and Rock		530	540	
Gray Clay		540	560	
Brown and Gray Clay and Rock		560	580	
Brown and Gray Clay		580	600	
Green Clay and Black Rock		600	620	
Gray Clay		620	630	
Multi-Colored Rock		630	660	
Multi-Colored Rock and Gray Clay		660	680	
Multi-Colored Rock		680	716	
Multi-Colored Fractured Rock		716	900	
NAD-27 GPS				
39.743860°N				
119.557215°W				

RECEIVED 2010 MAY 11 AM 11:20 STATE ENGINEER'S OFFICE

Notes: WGS -84GPS: Lat.: N39 44.625 Long.: W119 33.493.
Original Well Log # 68509 Final Pumping on 4/13/2010
Deepening of Well Log 68509

Date Started 10/15/2009 Date Completed 3/22/2010

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	60	700	2.25

8. WELL CONSTRUCTION
Depth Drilled 900 Depth Cased 900

HOLE DIAMETER (BIT SIZE)
6 Inches 210 Feet 716 Feet
4-1/2 Inches 716 Feet 900 Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
5"	9.66	.188	180	716
3-1/2"	8.01	.250	711	900

PERFORATIONS:
Type Perforation Fact.Torch Size Perforation
From F636 Feet to 656 Feet
From F676 Feet to 696 Feet
From T737 Feet to 879 Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth exists
PLACEMENT METHOD: [ ] Pumped [ ] Poured
SEAL TYPE: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout [ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 210 Feet to 900 Feet

9. WATER LEVEL
Static Water Level 180 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2187
Signed
By driller performing actual drilling on site or contractor
Dated 4/21/2010

MMN (F) PLI