

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64799

1. OWNER Robert E. Bastell ADDRESS AT WELL LOCATION Orovada NV,
 MAILING ADDRESS P.O. Box 130
Orovada NV, 89425
 2. LOCATION SE ¼ NE ¼ Sec. 4 T. 43 R. 36 E. Humboldt County
 PERMIT NO. 78007 Parcel No. 03-391-02 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & Sand	NO	0	30	30
Gravel & Sand	YES	30	80	50
Clay	NO	80	90	10
Gravel	YES	90	100	10

NAD-27 GPS
 41.635687° N
 117.926922° W

N 41° 38.135
 W 117° 55.674

NAD 83/WGS 84

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 7/8 Inches 0 Feet 100 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>Steel</u>	<u>.188</u>	<u>0</u>	<u>15</u>
<u>6 7/8</u>	<u>PVC</u>	<u>Sched 40</u>	<u>15</u>	<u>100</u>

Perforations:
 Type perforation hand cut slot
 Size perforation .125
 From 60 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 100 feet

9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Alternative Drilling Contractor
 Address 197 Western Hills
Spring Ck Nevada Contractor
 Nevada contractor's license number issued by the State Contractor's Board 73955
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
 Signed Arda Monty
 By driller performing actual drilling on site or contractor
 Date 5-10-10

Date started 4-12, 2010
 Date completed 4-25, 2010

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air Lift</u>	<u>30</u>	<u>0</u>	<u>6</u>

RECEIVED
 2010 MAY 13 AM 11:09
 STATE ENGINEERS OFFICE