FINALIZED MH

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110692
Permit No.
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64378

1. OWNER Pilot Travel Centers, LLC
MAILING ADDRESS 5508 Lonas Rd.
Knoxville, TN. 37909

ADDRESS AT WELL LOCATION 5625 West I-80
Winnemucca, NV. 89445
Subdivision Name: County: Humboldt

2. LOCATION NE ¼ NE NW Sec 9 / 10 T 35 D/S R 37 E
PERMIT/WAIVER No. FNCH 5-000212 013-081-04
Issued by Water Resources Parcel No.

Latitude N 40.930460°
Longitude W 117.806000°
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silts	No	0	5	5
silts sand Gravel	No	5	10	5
sand silt	Yes	10	15	5
sands Gravel	Yes	15	20	5
sands	Yes	20	30	10
AS-5				

Date started: April 7th, 20 10
Date completed: April 7th, 20 10

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH. 40	0	25

Perforations:
Type of perforation Factory Slot
Size of perforation .020
From 25 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 20 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 23 to 30 ☐ Pumped ☒ Poured
Type: 10/20 Silica Sand
Bentonite Chips: ☒ Yes ☐ No 20 to 23 ☐ Pumped ☒ Poured
Type: 3/4 Coated Pellets

7. Water Level
Static water level: 14 feet below land surface
Artesian Flow: NO G.P.M. P.S.I.
Water Temperature: 85 °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE
2010 MAY -5 AM 11:03
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc (Contractor)
Address P.O. Box 440 (Contractor)
Meridian Id 83680
Nevada contractor's license number issued by the *State Contractor's Board* 0038018
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* m-1803T-1
Signed (By driller performing actual drilling on site or contractor)
Date 4/25/10

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY 40.930557° N
117.805035° W
NAD 27