

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110697
Permit No. _____
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 104377

1. OWNER Pilot Travel Centers, LLC ADDRESS AT WELL LOCATION 5625 West I-80
MAILING ADDRESS 5508 Lonas Rd WINNEMUCA, NV 89445
KNOXVILLE, TN 37909 Subdivision Name: _____ County: Humboldt

2. LOCATION SE 1/4 28th Sec 4 S T 35 R 37 E Latitude N 40.93095° UTM E NAD 27
PERMIT/WAIVER No. FACT 5-000212 013-081-04 Longitude W 117.80555° N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silt Sand</u>	<u>NO</u>	<u>0</u>	<u>5</u>	<u>5</u>
<u>Silt</u>	<u>NO</u>	<u>5</u>	<u>10</u>	<u>5</u>
<u>Silt Sand Gravel</u>	<u>Yes</u>	<u>10</u>	<u>15</u>	<u>5</u>
<u>Sand Gravel</u>	<u>Yes</u>	<u>15</u>	<u>20</u>	<u>5</u>
<u>sand</u>	<u>Yes</u>	<u>20</u>	<u>30</u>	<u>10</u>
<u>AS-11</u>				

9. WELL CONSTRUCTION

Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>8</u>	<u>0</u>	<u>30</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>SCH. 40</u>	<u>0</u>	<u>25</u>

Perforations:

Type of perforation Fracture Slot
Size of perforation 0.70

From 25 feet to 30 feet
From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured
 Cement Grout 0 to 20 Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 23 to 30 Pumped Poured
Type: 10/20 silica sand

Bentonite Chips: Yes No 20 to 23 Pumped Poured
Type: 3/8 coated pellets

Date started: April 13th 20 10
Date completed: April 13th 20 10

7. Water Level

Static water level: 14 feet below land surface
Artesian Flow: NO G.P.M. _____ P.S.I. _____
Water Temperature: 68.5 °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
STATE ENGINEERS OF NV
2010 MAY 5 AM 11:04

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HAZ-Tech Drilling, Inc. Contractor
Address 700 Box 940 Contractor
Meridian, Id. 83680
Nevada contractor's license number _____
issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-18037-1

Signed David J. Longabaugh
By driller performing actual drilling on site or contractor
Date 4/25/10