

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110703
Permit No. _____
Basin 070

FINALIZED MA

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64378

1. OWNER Pilot Travel Centers, LLC ADDRESS AT WELL LOCATION 5625 West T-90
MAILING ADDRESS 5508 Longs Rd Winneemucca, NV 89445
Knoxville, TN 37909 Subdivision Name: _____ County: Humboldt

2. LOCATION NE 1/4 NE 1/4 Sec 37 T 35 S R 37 E Latitude N 40.93053° UTM E NAD 27
PERMIT/WAIVER No. FCA 5-000212 013-091-04 Longitude W 117.80567° N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test Stock
 Municipal/Industrial Monitor

5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>silt gravel</u>	<u>NO</u>	<u>0</u>	<u>5</u>	<u>5</u>
<u>silt</u>	<u>NO</u>	<u>5</u>	<u>10</u>	<u>5</u>
<u>silt sand</u>	<u>Yes</u>	<u>10</u>	<u>15</u>	<u>5</u>
<u>sand gravel</u>	<u>Yes</u>	<u>15</u>	<u>20</u>	<u>5</u>
<u>sand</u>	<u>Yes</u>	<u>20</u>	<u>25</u>	<u>5</u>
<u>VE-6</u>				

9. WELL CONSTRUCTION

Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>12</u>	<u>0</u>	<u>25</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>Sch. 40</u>	<u>0</u>	<u>10</u>

Perforations:

Type of perforation Factory slot
Size of perforation .020

From	feet to	feet
<u>10</u>	<u>25</u>	

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured
 Cement Grout 0 to 6 Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 8 to 25 Pumped Poured
Type: 10/20 silica sand
Bentonite Chips: Yes No 6 to 8 Pumped Poured
Type: 30 Bentonite Chips

7. Water Level
Static water level: 14 feet below land surface
Artesian Flow: NO G.P.M. _____ P.S.I. _____
Water Temperature: 63.5 °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
2010 MAY -5 AM 11:04
STATE ENGINEERS OFFICE

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Haz-Tech Drilling, Inc. Contractor
Address P.O. Box 940 Contractor
Meridian, ID 83680
Nevada contractor's license number _____
issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-14037-1

Signed David Bonds
By driller performing actual drilling on site or contractor
Date 4/25/10