WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

Finalized MH

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110828
Permit No.
Basin 070

NOTICE OF INTENT NO. 48529 (I)

1. OWNER Allied General
MAILING ADDRESS 1220 East Olive Ave. Fresno CA. 93728
ADDRESS AT WELL LOCATION 6335 Rosecreek Hwy Winnemucca NV. 89445 lot 22

2. LOCATION SW ¼ SE ¼ Sec. 9 T. 35N D/S R. 37 E. Humboldt County
PERMIT NO. Issued by Water Resources
13-065-04 Parcel No.
Broken Arrow Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Clay		5	105	100
Cemented Gravel	105	105	140	35

GPS N 40° 55.146
W 117° 49.266
NAD 27

40.919,100°N NAD27 O.O.
117.821,100°W

Date started 6-13, 2008
Date completed 6-16, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		4 hours

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188 Steel	0	20
6 5/8	Sched 40	PVC F480	20	140

Perforations:
Type perforation ~~1/8" x 3"~~ Hand cut
Size perforation 1/8" x 3"
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 74 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Firstgold Corp. Contractor
Address 1055 Cornell P.O. Box 6 Contractor
Lovelock NV. 89415
Nevada contractor's license number 007102 issued by the State Contractor's Board
Nevada driller's license number 730 issued by the Division of Water Resources, the on-site driller
Signed By driller performing actual drilling on site or contractor
Date 7-3-08

RECEIVED 2008 JUL -9 AM 10:24
STATE ENGINEERS OFFICE

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627