STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Finalized MH

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110831
Permit No.
Basin 091

NOTICE OF INTENT NO. 60985

1. OWNER Cheryl and Harold Hall
MAILING ADDRESS 2384 Red Maple Ct.
Reno NV 89523

ADDRESS AT WELL LOCATION 517 Crystal Peak Rd
Verdi, NV
Subdivision Name: County: Washoe

2. LOCATION ne ¼ SE ¼ Sec 18 T 19N N/S R 18 E
PERMIT/WAIVER No. 038-081-14
Issued by Water Resources Parcel No.

Latitude 39.51143
Longitude 119.99413
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
boulders		0	25	
rock/clay		25	210	
clay		210	265	
rock		265	295	

39.511, 521°N NAD27 D.D.
119.993, 096°W

RECEIVED 2008 JUL -2 AM 11:43 STATE ENGINEER'S OFFICE

Date started: 9-May, 20 08
Date completed: 21-May, 20 08

9. WELL CONSTRUCTION
Depth Drilled 295 Feet Depth Cased 295 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	100	Feet
8 3/4	Inches	100	Feet	295	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.97	1.88	+ 1 1/2	295

Perforations:
Type of perforation factory
Size of perforation 3/32
From 275 feet to 295 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 100 to 295 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 15 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	85	30 min
20	110	1 hr
30	280	3.5 hrs

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling, Inc (Contractor)
Address 4850 Joule St. Suite A5 (Contractor)
Reno, NV 89502
Nevada contractor's license number issued by the *State Contractor's Board* 14170
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 786
Signed (By driller performing actual drilling on site or contractor)
Date 2/13/2008

(Rev. 06-08)

USE ADDITIONAL SHEETS IF NECESSARY