

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110847
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34920

1. OWNER Silver Nugget Holding Inc. MAILING ADDRESS 2140 North Las Vegas Blvd Las Vegas, Nevada 89030			ADDRESS AT WELL LOCATION Las Vegas, Nevada 89030 Subdivision Name: IW-6 County: Clark		
2. LOCATION NW ¼ NE ¼ Sec 23 T 20S N/S R 61 E	PERMIT/WAIVER No. H-000372	Parcel No. 139-23-601-025	Latitude 36.19973 N	UTM E <input checked="" type="checkbox"/> NAD 27	<input type="checkbox"/> NAD 83/WGS 84
Issued by Water Resources			Longitude -115.12210 W		

3. WORKED PERFORMED <input checked="" type="checkbox"/> New Well <input type="checkbox"/> Replace <input type="checkbox"/> Recondition <input type="checkbox"/> Deepen <input type="checkbox"/> Other	4. PROPOSED USE <input type="checkbox"/> Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> Municipal/Industrial <input checked="" type="checkbox"/> Monitor <input type="checkbox"/> Stock	5. WELL TYPE <input type="checkbox"/> Cable <input type="checkbox"/> Rotary <input type="checkbox"/> RVC <input type="checkbox"/> Air <input checked="" type="checkbox"/> Other
---	--	---

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Fill Sandy Gravel w/ Silt		0	1	1
Silty Sand - brn		1	2	1
Fill Clayey Sand - brn		2	4	2
Sandy Clay - brn to ltbrn		4	13	9
Clayey Silt - white		13	18	5
Caliche - white		18	23	5
Sandy Clay - grey to ltgrey	x	23	28	5
Fat Clay - brn		28	33	5

JUN 11 2010 RECEIVED
APR 05 2010
LAS VEGAS OFFICE

9. WELL CONSTRUCTION				
Depth Drilled	33	Feet	Depth Cased	33
HOLE DIAMETER (BIT SIZE)				
From 8		Inches	To 0	Feet
To 33		Inches	Feet	
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1	0.50 inch	Stainless Steel Tubing	0	30
1	0.50 inch	Stainless Steel Tubing	0	26
Perforations:				
Type of perforation	1" OD Factory Slotted Stainless Steel			
Size of perforation	0.01			
From 30	feet to 33	feet		
From 26	feet to 28	feet		
From	feet to	feet		
From	feet to	feet		
From	feet to	feet		
Annular Seal: <input type="checkbox"/> Yes <input type="checkbox"/> No				
<input type="checkbox"/> Neat Cement	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
<input type="checkbox"/> Cement Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
<input type="checkbox"/> Concrete Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
<input type="checkbox"/> ≥30% Bentonite Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
Gravel Pack: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	26/30	to 28/33	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Type:	Number 3 Cemex Sand			
Bentonite Chips: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	0/28	to 26/30	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Type:	3/8" Poly Plug Bentonite Pellets			

7. Water Level
Static water level: 23 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA			
TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION	
This well was drilled under my supervision and the report is true to the best of my knowledge.	
Name	Terracon Consultants
Address 750 Pilot Road Suite F Las Vegas Nevada 89119	
Nevada contractor's license number issued by the State Contractor's Board _____	
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2409	
Signed	<u>Reeshel Secker</u>
By driller performing actual drilling on site or contractor	
Date	4-3-2010

(Rev. 06-06)

USE ADDITIONAL SHEETS IF NECESSARY