STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110851
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34920

1. OWNER Silver Nugget Holding Inc.
MAILING ADDRESS 2140 North Las Vegas Blvd
Las Vegas, Nevada 89030

ADDRESS AT WELL LOCATION
Las Vegas , Nevada 89030
Subdivision Name: IW-10 County: Clark

2. LOCATION NW ¼ NE ¼ Sec 23 T 20S N/S R 61 E
PERMIT/WAIVER No. H-000372 (Issued by Water Resources) 139-23-601-025 Parcel No.

Latitude 36.199800 N
Longitude -115.12193 W
UTM E
N
[x] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [x] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Sandy Gravel w/silt		0	1	1
Fill Silty Sand w/ gravel		1	3	2
Fill Clayey Sand - brown		3	7	4
Sandy Clay - white		7	14	7
Caliche - white		14	19	5
Sandy Clay - white		19	20	1
Caliche - white		20	21	1
Sandy Clay - ltgrey to grey	x	21	25	4
Sandy Clay - brown		25	28	3
Fat Clay - brown		28	33	5

SNWA
RECEIVED
APR 05 2010
LAS VEGAS OFFICE

Date started: 25-Mar , 20 10
Date completed: 25-Mar , 20 10

9. WELL CONSTRUCTION
Depth Drilled 33 Feet Depth Cased 33 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	33	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	Sch 40	PVC	0	18

Perforations:
Type of perforation Slotted
Size of perforation 0.020
From 18 feet to 33 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [ ] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 16 to 33 [ ] Pumped [x] Poured
Type: Number 12 Orange County Silica Sand
Bentonite Chips: [x] Yes [ ] No 1 to 16 [ ] Pumped [x] Poured
Type: 3/8" Hole Plug Bentonite Chips

7. Water Level
Static water level: 21.1 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants (Contractor)
Address 750 Pilot Road Suite F Las Vegas Nevada 89119 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board*
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2409
Signed (By driller performing actual drilling on site or contractor)
Date 3-29-2010

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY