STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110870
Permit No. —
Basin 055

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65088

1. OWNER Centeral Nevada Hay Company
MAILING ADDRESS 6822 S. Starlite Dr. Morrison,CO

ADDRESS AT WELL LOCATION Dorthy Dowble Wide Well
Antelope Valley, NV
Subdivision Name: County: Lander

2. LOCATION SW SE Sec14T25N/ R42E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 007-53-016 (Parcel. No.)

Latitude 40°01.943 UTM E ☐ NAD 27
Longitude 117°12.852 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		295	305	10
Void lost circulation		305	307	2
Clay		307	315	8
Sand/fine gravel		315	320	5
Clay		320	340	20
Sand/gravel w/clay streamers	X	340	390	50

GPS NAD-27
40.032465°N
117.213266°W

RECEIVED 2010 APR -6 AM 11:07 STATE ENGINEERS OFFICE

Date started: March 23, 20 10
Date completed: March 29, 20 10

7. Water Level
Static water level: 192 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		5

9. WELL CONSTRUCTION
Depth Drilled 295-390 Feet Depth Cased 390 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/8 Inches	295 Feet	390 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	8	188	290	390

Perforations:
Type of perforation Factory Cut Slots
Size of perforation 3/32X4
From 350 feet to 390 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement Exist to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No Natural to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling Inc
By driller performing actual drilling on site or contractor
4-2-2010

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

MO-I
MH-F