Finalized MH

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Corrected

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110889
Permit No. 78529
Basin 101

(1)

NOTICE OF INTENT NO. 64702

1. OWNER Thurman Hiskett
MAILING ADDRESS P.O. Box 5009
Fallon, NV 89407

ADDRESS AT WELL LOCATION 2304 Allen RD
Fallon, NV 89406
Subdivision Name: County: Churchill

2. LOCATION SE ¼ NE ¼ Sec 2 T 18N N/S R 28 E
PERMIT/WAIVER No. 78529
Issued by Water Resources 006-211-49 Parcel No.

Latitude 39.45611
Longitude -118.80248
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand & Gravel		1	12	11
Brown Clay		12	26	14
Black Sand W/Clay		26	47	21
Black Clay		47	85	38
Brown Gravel & Sand	X	85	110	25

GPS NAD-27
39.456192° N
118.801494° W

Date started: 13-Dec, 20 09
Date completed: 15-Dec, 20 09

7. Water Level
Static water level: 10 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14 7/8	Inches	0	Feet	110	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	~~8.26~~ 16.96	~~.500~~ .188	~~0~~ 1	110

Perforations:
Type of perforation Mill Cut
Size of perforation 1/8"
From 100 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	10 to 0		☒ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☒ ≥30% Bentonite Grout	10 to 100		☒ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 110 ☐ Pumped ☒ Poured
Type: 3/8" pea gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89406
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* Gabe King #2285
Signed (By driller performing actual drilling on-site or contractor)
Date 1/7/2010

(Rev. 05-09)

USE ADDITIONAL SHEETS IF NECESSARY

(10)-1