

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 111223
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35143

1. OWNER CV Propco LLC %GenCounsel
MAILING ADDRESS 1505 S. Pavilion Center
Las Vegas, NV 89135

ADDRESS AT WELL LOCATION 3564 W. Naples Dr.
RW-3 Paradise nv
Subdivision Name: _____ County: Clark

2. LOCATION NW ¼ SW ¼ Sec 20 T 21S N/S R 61 E
PERMIT/WAIVER No. 16220301010
Issued by Water Resources Parcel No. _____

Latitude 36 06'24.14"N UTM E NAD 27
Longitude 115 11'12.21"W N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Fill		0	3	3
Clayey Sand		3	5	2
Sandy Clay		5	11	6
Clayey Sand		11	13	2
Caliche		13	15	2
Clayey Sand		15	20	5
Sandy Clay		20	26	6
Clayey Silt		26	27	1
Caliche		27	28	1
Silty Clay		28	35	7
Sandy Clay		35	43	8

9. WELL CONSTRUCTION				
Depth Drilled	Feet	Depth Cased	Feet	
<u>43</u>		<u>43</u>		
HOLE DIAMETER (BIT SIZE)				
	From		To	
<u>10</u>	Inches	<u>0</u>	Feet	<u>43</u> Feet
	Inches		Feet	Feet
	Inches		Feet	Feet
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>		<u>Sch 40</u>	<u>0</u>	<u>43</u>

Perforations:
Type of perforation Factory Slotted
Size of perforation .020
From 23 feet to 43 feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 21 to 43 Pumped Poured
Type: #3 Monterey Sand

Bentonite Chips: Yes No 1 to 21 Pumped Poured
Type: Medium Bentonite Chips

7. Water Level
Static water level: 32 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: n/a °F
Quality: good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 570 Corinthian Way
Contractor
N. Las Vegas, NV, 89030
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2381
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 12-28-09

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			<u>.5</u>