STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111241
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32469

1. OWNER U-HAUL REALESTATE COMPANY
MAILING ADDRESS P.O. BOX 29046 PHOENIX AZ. 85038
ADDRESS AT WELL LOCATION 2021 W. BONANZA LAS VEGAS NV.
Subdivision Name: County: CLARK

2. LOCATION SW ¼ SW ¼ Sec 28 T 20 N/S R 61 E
PERMIT/WAIVER No. 1392840023
Issued by Water Resources Parcel No.
Latitude 36° 10 36 94
Longitude 115° 10 05 83
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	.25	.25
SAND + STONE FILL		.25	1.0	.75
SILT SAND & GRAVEL		1.0	8.0	7.0
CALCHE		8.0	10.0	2.0
MOIST CALCHE		10.0	16.5	6.5
MOIST CLAY + CALCHE	YES	16.5	20.0	13.5

FEB 05 2010

FACILITY ID. NO
8-000708

AS-3

Date started: 2-1, 20 10
Date completed: 2-1, 20 10

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	30

Perforations:
Type of perforation MACHINE SLOT
Size of perforation .020
From 25 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout 1 to 22 ☐ Pumped ☒ Poured
☐ Concrete Grout 0 to 1 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 24 to 30 ☐ Pumped ☒ Poured
Type: #3
Bentonite Chips: ☒ Yes ☐ No 22 to 24 ☐ Pumped ☒ Poured
Type: 3/8"

7. Water Level
Static water level: 18.5' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING
Contractor
Address 7150 PLACID ST.
Contractor
LAS VEGAS NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed Michael Winkler
By driller performing actual drilling on-site or contractor
Date 2-3-2010

(Rev. 06-06)
USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)
(O) 627