

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32762

1. OWNER Joe Higbee ADDRESS AT WELL LOCATION 1187 Bar X Bar  
 MAILING ADDRESS P.O. Box 354 Alamo NV 89001 Rd Alamo NV  
 2. LOCATION NW 1/4 SW 1/4 Sec 32 T 6 R 61 E Lincoln County  
 PERMIT NO. 35453 011-210-10 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_


6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravel boulders	Y	80	130	50
gravel-clay	X	130	176	46
GPS WGS 84 N 37° 22.920' W 115° 10.275'				

8. WELL CONSTRUCTION  
 Depth Drilled 176 Feet Depth Cased 176 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 3/4 Inches To 0 Feet 176 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>176</u>

 Perforations:  
 Type perforation Screen  
 Size perforation .020  
 From 46' feet to 56' feet  
 From 66' feet to 76' feet  
 From 86' feet to 166' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet



Date started 3-24-2010, 20 \_\_\_\_\_  
 Date completed 3-29-2010, 20 \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>70</u>		<u>2</u>

9. WATER LEVEL  
 Static water level 24' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality poor

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Davis Drilling and Pumps Contractor  
 Address HC 61 Box 54 Hiko NV 89017 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0028266  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
 Signed Mike Davis  
 By driller performing actual drilling on site or contractor  
 Date 3-29-2010