WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 111418
Permit No.
Basin 137A

NOTICE OF INTENT NO. 61859 (1)

1. OWNER William & Diana Olsen
MAILING ADDRESS 5236 Venita Dr. Las Vegas, NV 89120
ADDRESS AT WELL LOCATION 1800 Cloverdale Rd. 38° 22.816 N 117° 25.647 W Peavine Rd. Tonopah, NV

2. LOCATION SE ¼ NE ¼ Sec. 13 T. 6 (N)S R. 40 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 012-421-38 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blk Md-Coarse Sand. 3/8-1/2" gravel		0	25	25
10% Clay. 90% Coarse-Md. sand		25	40	15
20% Gravel. 80% Coarse sand		40	80	40
50% Gravel. 50% Coarse Sand		80	130	50
10% Gravel. 90% Coarse Sand sub rounded	✓	130	160	30
5% Gravel 5% Fine Sand 90% coarse-md. sand	✓	160	200	40

38.380,337°N NAD27 D.D.
117.426,522°W

Date started July 21, 2010
Date completed July 21, 2010

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
7-21-10	50		1 Hr.

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
9 7/8	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	17.02	.250	+18"	20
6.625	5.006	.390	20	200

Perforations:
Type perforation Mill
Size perforation 1/8"
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Brothers Drilling (Contractor)
Address PO Box 965 (Contractor) Enterprise, UT 84725
Nevada contractor's license number issued by the State Contractor's Board 0068459
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1710
Signed Dale Gardner (By driller performing actual drilling on site or contractor)
Date 7-22-10

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY MMH (F) (O)-627