

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63553

1. OWNER Chuck Harris ADDRESS AT WELL LOCATION Corner of Mustang Ave and Senity Courts
 MAILING ADDRESS PO. Box 1794 Round Mtn NV 89095
 2. LOCATION SW 1/4 SE 1/4 Sec. 4 T. 10 N. R. 43 E. Nye County
 PERMIT NO. _____ Issued by Water Resources Parcel No. 12 461 11 Subdivision Name Senity Courts

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	8	8
Clay		8	30	22
Clay sand		30	55	25
Sand Gravel Boulders	X	55	80	25
Clay		80	95	15
Sand Boulders	X	95	140	45
Clay		140	145	5

CPS WGS 84
 N 38° 43' 04" W
 W 117° 09' 30" E

38.750742° N NAD27 D.O.
 117.154111° W

8. WELL CONSTRUCTION
 Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 145 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>145</u>

Perforations:
 Type perforation saw cut
 Size perforation 1 1/2" x 3"
 From 6.5 feet to 145 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 145 feet

Date started 5-18, 2010
 Date completed 5-19, 2010

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Minutes)
<u>60</u>	<u>10.1</u>	<u>1</u>

RECEIVED
 MAY 24 PM 1:49
 STATE ENGINEER

9. WATER LEVEL
 Static water level 26 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling and Pumps Contractor
 Address HC 61 Box 54 Hiko NV Contractor
89017
 Nevada contractor's license number issued by the State Contractor's Board 9968200
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1371
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 5-20-2010