

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111457
Permit No. -
Basin 072

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65930

1. OWNER Travel Centers of America ADDRESS AT WELL LOCATION Mill City Truck Stop 6000 E Frontage Rd
MAILING ADDRESS 24601 Center Ridge Rd Mill City NV 89418
Subdivision Name: _____ County: Pershing

2. LOCATION N 1/4 NW 1/4 Sec 33 T 33 R/S R 35 E Latitude N 40.69376 UTM E NAD 27
PERMIT/WAIVER No. Fact# 5-000014 008-130-01 Longitude W 118.05678 N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED New Well Replace Recondition Deepen Other
4. PROPOSED USE Domestic Irrigation Test Monitor Municipal/Industrial Stock
5. WELL TYPE Cable Rotary RVC Other hollow stem Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>silt sand</u>	<u>NO</u>	<u>0</u>	<u>5</u>	<u>5</u>
<u>silt sand Gravel</u>	<u>NO</u>	<u>5</u>	<u>10</u>	<u>5</u>
<u>sandy silt</u>	<u>NO</u>	<u>10</u>	<u>15</u>	<u>5</u>
<u>silt sand Gravel</u>	<u>NO</u>	<u>15</u>	<u>30</u>	<u>15</u>
<u>sandy Gravel</u>	<u>NO</u>	<u>30</u>	<u>40</u>	<u>10</u>
<u>silty sand Gravel cemented</u>	<u>yes</u>	<u>40</u>	<u>75</u>	<u>35</u>
<u>silt sand Clay cemented</u>	<u>yes</u>	<u>35</u>	<u>85</u>	<u>10</u>

DR-5

NAD-27 GPS
40.693855°N
118.055807°W

9. WELL CONSTRUCTION

Depth Drilled 85 Feet Depth Cased 81 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>8"</u>	<u>0</u>	<u>85</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>sch 40</u>	<u>0</u>	<u>46</u>

Perforations:

Type of perforation Factory slot
Size of perforation 1/2"

From 46 feet to 81 feet
From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement 0 to 42 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 44 to 85 Pumped Poured
Type: 10/20 silica sand
Bentonite Chips: Yes No 42 to 44 Pumped Poured
Type: 3/8 Bentonite chips

Date started: 7/13 Date completed: 7/14

7. Water Level

Static water level: 42 feet below land surface
Artesian Flow: NO G.P.M. _____ P.S.I. _____
Water Temperature: 69.5 °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Haz-Tech Drilling Inc Contractor
Address Po Box 940 Contractor
Meridian, Id 83680
Nevada contractor's license number 0038018
issued by the State Contractor's Board
Nevada driller's license number issued by the 2412-m-LTD
Division of Water Resources, the on-site driller
Signed [Signature]
By driller performing actual drilling on-site or contractor
Date 7/22/10