STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111632
Permit No. –
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66089

1. OWNER City of Carson City
MAILING ADDRESS 3505 Butti Way Carson City, NV 89701

ADDRESS AT WELL LOCATION 400 S. Carson St. Legislative Mall Area
MW-4 Carson City, NV
Subdivision Name: County: Carson City

2. LOCATION NW ¼ SW ¼ Sec 17 T 15N N/S R 20 E
PERMIT/WAIVER No. 004-071-01
Issued by Water Resources Parcel No.

Latitude 39°09'46.92" N
Longitude 119°46'00.56" W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dry silty brown clay		0	30	30
NAD-27 GPS				
39.163124 °N				
119.765808 °W				

Date started: 21-Jul, 20 10
Date completed: 21-Jul, 20 10

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8" &	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		Sch 40	0	30
2"				

Perforations:
Type of perforation Slot
Size of perforation .010
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 11 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 13 to 30 ☐ Pumped ☒ Poured
Type: #2/12 Sand
Bentonite Chips: ☒ Yes ☐ No 11 to 13 ☐ Pumped ☒ Poured
Type: Medium

7. Water Level
Static water level: N/A feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PC Exploration
Contractor
Address 2905 Lesvos Court
Contractor
Lincoln, CA 95648
Nevada contractor's license number issued by the *State Contractor's Board* 28767
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-1935
Signed
By driller performing actual drilling on site or contractor
Date 20-Aug-10

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

PLO.