

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 111858  
 Permit No. \_\_\_\_\_  
 Basin 162

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **35429**

1. OWNER **MICHEAL & VIRGINA VON QUILICH** ADDRESS AT WELL LOCATION **1711 N CHICO LN**  
 MAILING ADDRESS **1711 N CHICO LN**  
**PAHRUMP NV, NV 89060**

2. LOCATION **SW** 1/4 **NE** 1/4 Sec. **4** T **20** **W** R **53** E **NYE** County  
 PERMIT NO. **35-051-25** Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  
 Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
EXISTING		0	100	100
CLAY		100	130	30
CALICHIE	WB	130	145	15
CLAY		145	165	20
CALICHIE	WB	165	205	40
CLAY		205	230	25
CALICHIE	WB	230	245	15
CLAY		245	255	10
CALICHIE	WB	255	265	10
CLAY		265	275	10
CALICHIE	WB	275	290	15
CLAY		290	300	10

N36°14'41.4"  
 W116°01'14.2"  
 EXISTING 8" STELL WELL

8. WELL CONSTRUCTION  
 Depth Drilled **300** Feet Depth Cased **300** Feet

HOLE DIAMETER (BIT SIZE)  
 EXISTING From 0 To 100 Feet  
**7-7/8** Inches From 100 To 300 Feet  
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	16.94	.188	0	100
4.5"	2.37	.248	100	300

Perforations:  
 Type perforation **SCREEN**  
 Size perforation **.020**

From	160	feet to	200	feet
From	220	feet to	260	feet
From	280	feet to	300	feet
From		feet to		feet
From		feet to		feet

Surface Seal:  Yes  No  
 Depth of Seal **EXISTING**  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout

Gravel Packed:  Yes  No  
 From **100** feet to **300** feet

9. WATER LEVEL  
 Static water level **70** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.**  
 Contractor

Address **1220 E MANSE RD**  
 Contractor  
**PAHRUMP, NV. 89048**  
 Nevada contractor's license number issued by the State Contractor's Board **47333**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**  
 Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date **8/2/2010**

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DEPT/ENV  
 RECEIVED  
 AUG 05 2010  
 LAS VEGAS OFFICE

Date started **8/2/2010**, 19  
 Date completed **8/2/2010**, 19