STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111895
Permit No. —
Basin 083

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65932

1. OWNER Waste Management
MAILING ADDRESS 2401 Canyon way
Sparks NV 89434

ADDRESS AT WELL LOCATION Lockwood Regional Landfill
Subdivision Name:
County: Storey

2. LOCATION: NE, SW Sec 23 T 19 N/S R 21 E
PERMIT/WAIVER No. SW 214 R01 (Issued by Water Resources) 004-131-04 (Parcel No.)

Latitude N 39.49635°
Longitude W 119.60090°
UTM E
N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Sand	No	0	5	5
Clay Gravel	No	5	15	10
Clay Gravel Sand	No	15	20	5
M-6				
NAD-27 GPS				
39.496437°N				
119.599884°W				

Date started: August 24th, 20 10
Date completed: August 24th, 20 10

9. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	20	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1/2		Sch 40	+3	10

Perforations:
Type of perforation Factory Slot
Size of perforation .020
From 10 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 6 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 3 to 20 ☐ Pumped ☒ Poured
Type: #8 Silica Sand
Bentonite Chips: ☒ Yes ☐ No 6 to 3 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite chips

7. Water Level
Static water level: N/A feet below land surface
Artesian Flow: NO G.P.M. P.S.I.
Water Temperature: N/A °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Haz-Tech Drilling Inc (Contractor)
Address P.O. Box 940 (Contractor)
Meridian Id 83680
Nevada contractor's license number issued by the State Contractor's Board 0035018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2413 S m-LTD
Signed (By driller performing actual drilling on-site or contractor)
Date 8/31/10

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-06)

(NSPO 3-08)

(O) 627