STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112125
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65578 (1)

1. OWNER: Bill Eder
MAILING ADDRESS: 521 10 th ave box 10
Caldwell Id 83605

ADDRESS AT WELL LOCATION: 3223 Muddy Rd
Winnemucca, Nv 89445
Subdivision Name: 0 County: Pershing

2. LOCATION SW ¼ SW ¼ Sec 3 T 34N N/S R 37E E
PERMIT/WAIVER No. 009-040-06 Parcel No.
issued by Water Resources

Latitude 40 50.623n
Longitude 117 48.720w
UTM E N
NAD 27 [X]

3. WORKED PERFORMED
[X] New Well Replace Recondition Deepen Other

4. PROPOSED USE
[X] Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
Cable [X] Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty loam		0	55	55
silt and sand		55	125	70
Sand and small gravel		125	140	15
		140		
40.843812ON NAD27				
117.811035OW				
				140.00

Date started: 10/9/2010
Date completed: 10/10/2010

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140

HOLE DIAMETER (BIT SIZE)

		From	To
10 7/8	inches	0 Feet	140 Feet
	inches	Feet	Feet
	inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	STEEL	.188	0	20
6.900	PVC	sdr21=.450 in	20	140

Perforations:
Type of perforation: 6 inch pvc mill horizontal slot screen
Size of perforation: 1/32
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: Yes

Neat Cement	to	Pumped		Poured
Cement Grout	4 to 10	Pumped	X	Poured
Concrete Grout	to	Pumped		Poured
≥30% Bentonite Grout	10 to 55	Pumped	X	Poured
Gravel Pack: [X] Yes No 55 to 140		Pumped	X	Poured
Type: 3/8 minus				
Bentonite Chips: [X] Yes No 10 to 55		Pumped	X	Poured
Type: 3/8 baroid				

7. Water Level
Static water level: 22 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: good

8. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift x

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	est 40	est 20	3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Contractor: High Desert Drilling LLC
Address Contractor: 4225 E Mary Way
Winnemucca Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board: 62237
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2140 & 2364
Signed By driller performing actual drilling on this or contract:
Date: 10/11/2010

USE ADDITIONAL SHEETS IF NECESSARY

MMH - (F)