

41.447020°N  
117.491923°W  
N49°27' (T)

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 112163  
Permit No. V09755  
Basin 069

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65989

1. OWNER **Rick Graham** ADDRESS AT WELL LOCATION **Camella Irwin Inspector**  
MAILING ADDRESS **PO Box 990 Winnemucca, NV** **Winnemucca, NV**

2. LOCATION **NE¼SW¼ Sec08T41N/ R40E** Latitude **N41°26.815** UTM E  NAD 27  
PERMIT/WAIVER NO. **V09755** Parcel No. **N/A** Longitude **W117°29.573** N  NAD 83/WGS 84  
*Issued by Water Resources*

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Other  
4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand/clay		0	8	8
Course gravel		8	30	22
Sand/gravel		30	50	20
Course gravel	X	50	110	60
Sand w/gravel		110	120	10
Course gravel	X	120	205	85

9. WELL CONSTRUCTION  
Depth Drilled **205** Feet Depth Cased **205** Feet  
HOLE DIAMETER (BIT SIZE)  
From **11** Inches To **0** Feet **205** Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	205

Perforations:  
Type of perforation **Factory Cut Slots**  
Size of perforation **3/32x4**  
From **165** feet to **205** feet  
From feet to feet  
From feet to feet  
From feet to feet

Annular Seal:  Yes  No  
 Neat Cement 0 to 50  Pumped  Poured  
 Cement Grout to  Pumped  Poured  
 Concrete Grout to  Pumped  Poured  
 ≥30% Bentonite Grout to  Pumped  Poured  
Gravel Pack:  Yes  No 100 to 205  Pumped  Poured  
Type:  
Bentonite Chips:  Yes  No 50 to 100  Pumped  Poured  
Type:

Date started: **Oct 12, 20 10**  
Date completed: **Oct 15, 20 10**

7. Water Level  
Static water level: **60** feet below land surface  
Artesian Flow: **N/A** G.P.M. **N/A** P.S.I.  
Water Temperature: **Cool** °F  
Quality: **Good**

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.			
<b>15-20</b>			
Draw Down (Feet Below Static)			
<b>4</b>			
Time (Hours)			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name **Fred Anderson Drilling, Inc.**  
(CONTRACTOR)

Address **10760 S. Grass Valley Road**  
(CONTRACTOR)  
**Winnemucca, NV 89445**  
Nevada contractor's license number issued by the State Contractor's Board **021467**  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2083**  
Signed *Fred Anderson Drilling Inc*  
By driller performing actual drilling on site or contractor  
Date **November 5, 2010**