WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 112184
Permit No.
Basin 156

NOTICE OF INTENT NO. 66409

1. OWNER Robert Nolan
MAILING ADDRESS HC 76 Box 6050
Tonopah NV 89049

ADDRESS AT WELL LOCATION NO 2 moores station Nye County NV

2. LOCATION ~~SW~~ ¼ ~~SE~~ ¼ Sec. 36 T. 10 N/S R. 51 E. NYE County
PERMIT NO. NE NW (Issued by Water Resources) 009-581-01 (Parcel No.) ⊖ (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand-Gravel		0	30	30
Hard Rock		30	45	15
sand-gravel-boulders	X	45	95	50
Hard Rock		95	115	20
Fractured Rock	X	115	135	20
Hard Rock		135	140	5

GPS WGS 84
N 38° 41.43.30
W 116° 11.22.50

38.690617°N NAD27
116.187029°W

Date started 10-25-2010, 20
Date complated 10-26 2010, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		2

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 1/2	PVC	Sch 40	0	140
8 5/8	16.96	.188	0	8

Perforations:
Type perforation sqw cut
Size perforation 1/8" x 3"
From 105 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 105 feet to 140 feet

9. WATER LEVEL
Static water level 29 feet below land surface
Artesian flow ⊖ G.P.M. ⊖ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 (Contractor)
Hiko NV 89017
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1181
Signed Mike Das (By driller performing actual drilling on site or contractor)
Date ~~10-25~~ - 11-7-2010

MMH-(F)