

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 112189
Permit No. 687
Basin

SEE LOG 112189

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. "_____"

1 OWNER Granite Construction
MAILING ADDRESS 1900 Glendale Ave
Sparks, NV 89431

ADDRESS AT WELL LOCATION Within the Truckee River, under HWY 395
Bridge Crossing
Subdivision Name: _____ County: Washoe

2 LOCATION NW 1/4 NW 1/4 Sec 7 T 19N N/S R 20 E
PERMIT/WAIVER No. DEW-87 Truckee River
Issued by Water Resources Parcel No.

Latitude 39 31'52.05" N UTM E NAD 27
Longitude 119 47'8.28" W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? no
If yes, what is replacement well NOI? _____
Is there an existing well log? _____
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	15	3/8	0	25

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made: _____

Existing Perforations:

From	Type of perforation	Size of perforation	feet to	feet
	machine	0.032		

Additional Perforations:

From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL
Static water level 0 feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS
Material Used
From _____ feet to _____ feet none Pumped Poured
From _____ feet to _____ feet Pumped Poured

6 Additional Notes or Comments

Well #1
This well was not abandoned per the normal State requirements. This temp. dewatering well was installed within the banks of the Truckee River in native gravels. We received the approval not to install a concrete slurry seal because it would effectively not seal anything based on the well location.

Neat Cement Fluid Weight _____ lbs/gal
Bentonite Grout _____ % bentonite
Date Started _____ n/a
Date Completed _____ n/a

2010 SEP 27 09:11:31
STATE ENGINEER

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name Viking Drillers Inc Contractor
Address 801 Northport Dr. Contractor
Sacramento, CA 95691
Nevada contractor's license number issued by the State Contractor's Board 0034680
Nevada driller's license number issued by the Division of Water Resources, the on-site driller none
Signed _____
By driller performing actual drilling on site or contractor
Date 9/24/2010