

well #9

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 112615
Permit No.
Basin 092 B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66171

1 OWNER SUSAN TURMES-CARLSTEN
MAILING ADDRESS 345 OREGON BLVD
RENO, NV 89506
ADDRESS AT WELL LOCATION 345 OREGON BLVD
RENO, NV 89506
Subdivision Name:
County: Washoe

2 LOCATION NW 1/4 SW 1/4 Sec 15 T 21N N/S R 19 E
PERMIT/WAIVER No. WL100072 080-357-06
Latitude 39.68626°N UTM E
Longitude 119.84670°W N
NAD 27
NAD 83/WGS 84

3 TYPE OF WELL
[X] Domestic
[Municipal/Industrial]
Irrigation
Monitor
Test
Stock
Is this well being plugged because a replacement well was drilled? NO
Is there an existing well log? YES
If yes, what is NDWR well log #? 25371

4 EXISTING WELL CONSTRUCTION
Depth Drilled 195 Feet
Depth Cased 195 Feet
EXISTING CASING SCHEDULE
Table with columns: Size O.D. (Inches), Weight/Ft. (Pounds), Wall Thickness (Inches), From (Feet), To (Feet)
Row 1: 6 5/8, 13.03, .188, +1, 195

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? [X] yes [ ] no
If well was not cleaned out to total depth, please explain why:
Was the well contaminated? [ ] yes [X] no
Was the casing pulled? [ ] yes [X] no
Was the casing over drilled? [ ] yes [X] no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:

Existing Perforations:
Table with columns: Type of perforation, Size of perforation, From, To
Row 1: FACTORY SLOT, 3X 3/32, From 135 feet to 195 feet

MILLS KNIFE
Table with columns: Type of perforator used, From, To, Number of perfs per linear foot
Row 1: From 90 feet to 134 feet, Number of perfs per linear foot 4

5 WATER LEVEL
Static water level 170 feet below land surface
Artesian flow
Water temperature POOR °F Quality POOR

8 WELL PLUGGING MATERIALS
Material Used
Table with columns: From, To, Material, Pumped, Poured
Row 1: From 90 feet to 195 feet, BENTONITE CHIPS, [ ] Pumped, [X] Poured
Row 2: From 0 feet to 90 feet, CEMENT GROUT, [X] Pumped, [ ] Poured

6 Additional Notes or Comments
BENTONITE CHIPS FROM BOTTOM TO 90'
CEMENT GROUT FROM 0 TO 90'
39.686351°N NAD27 O.D.
119.845673°W

Neat Cement Fluid Weight 96/4 lbs/gal
Bentonite Grout BENTONITE CHIP % bentonite
Date Started 12/15/2010
Date Completed 12/15/2010

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Address # 20 KIT KAT DRIVE
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [Signature]
Date 12/16/2010