

FAYED  
2-20-10

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 112626  
Permit No.  
Basin 059

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

63104 ①

NOTICE OF INTENT NO.

1. OWNER Edgar Hinton & David Itza ADDRESS AT WELL LOCATION 2052 PRESIDENTIAL BLVD  
MAILING ADDRESS P.O. Box 578 Subdivision Name: \_\_\_\_\_ County: LANDON  
BATTLE MTN NV 89820

2. LOCATION SE 1/4 SW 1/4 Sec 3 T 31 N/S R 45 E Latitude UTM E509101  NAD 27  
PERMIT/WAIVER No. IT400-38 Longitude N 4492133  NAD 83/WGS 84

Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Municipal/Industrial  Monitor  Stock  Air  Other

5. WELL TYPE

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
SANDY CLAY		5	40	35
Rocky clay SAND		40	60	20
SANDY CLAY		60	80	20

40.581836°N NAD 27 D.D.  
116.892465°W - GPS-

9. WELL CONSTRUCTION  
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)  
Inches From 0 To 80 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>80</u>

Perforations:  
Type of perforation SAWED  
Size of perforation  
From 60 feet to 80 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 5 to 55  Pumped  Poured  
 20% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 60 to 80  Pumped  Poured  
Type: \_\_\_\_\_

Bentonite Chips:  Yes  No 55 to 60  Pumped  Poured  
Type: 3/8

7. Water Level  
Static water level: 20 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: 60/62 °F  
Quality: G 000

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>ROTARY</u>	<u>40+</u>	<u>DMK</u>	<u>6 Hrs</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name LBJ DRILLING & PUMP COMPANY, INC. Contractor  
Address P.O. BOX 902 - Winnemucca, NV 89446 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0009605A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807  
Signed [Signature] By driller performing actual drilling on site or contractor Joe Boggio  
Date \_\_\_\_\_

RECEIVED  
2011 JAN 18 AM 11:33  
STATE ENGINEERS OFFICE

USE ADDITIONAL SHEETS IF NECESSARY

MMH-①  
③