

DEEPENING NDWR
WELL LOG # 17444

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112644
Permit No. 31885
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65070

1. OWNER South Crestview Homeowner Assn.
MAILING ADDRESS P.O. Box 381
Elko, NV. 89801

ADDRESS AT WELL LOCATION Crestview Drive

2. LOCATION SW 1/4 SW 1/4 Sec 7 T 34N N/S R 55 E
PERMIT/WAIVER No. 31885 083-003-008
Issued by Water Resources Parcel No.

Latitude 40. 50. 505N UTM E NAD 27
Longitude 115. 50. 001W N NAD 83 NAD 83/WGS 84
Subdivision Name: County: Elko

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other...

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other...

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Conglomerate		518	525	7
Soft Conglomerate	X	525	526	1
Green Clay		526	540	14
Conglomerate		540	583	43
Soft Conglomerate	X	583	584	1
Green Clay		584	592	8
Conglomerate		592	645	53
Green Clay		645	682	37
Conglomerate		682	715	33
Soft Conglomerate	X	715	716	1
Conglomerate		716	775	59
Black Sandstone		775	795	20
Conglomerate		795	808	13

8. WELL CONSTRUCTION				
Depth Drilled	Feet	Depth Cased	Feet	
515		808		
HOLE DIAMETER (BIT SIZE)				
7 7/8	Inches	518	Feet	808
	Inches		Feet	
	Inches		Feet	
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	PVC	SDR-17	503	808

Perforations:		Screen	
Type of perforation	Size of perforation	From	To
	0.032	500	808
From		feet to	feet
From		feet to	feet
From		feet to	feet
From		feet to	feet
From		feet to	feet

9. WATER LEVEL
Static water level 420 feet below land surface
Artesian flow _____ G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sharel C. Fertig Sr., dba Fertig Drilling Company
Contractor
Address P.O. Box 525
Contractor
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 15847
Signed *Sharel C. Fertig Sr.*
By driller performing actual drilling on site or contractor
Date 1-15-11

Date started 2-Dec '10
Date completed 13-Dec '10

7. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Approx	25		24

STATE ENGINEERS OFFICE
2011 JAN 24 AM 11:37
RECEIVED

USE ADDITIONAL SHEETS IF NECESSARY
40.841830° N
115.832446° W
NAD 83 (TA)