WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

112650
OFFICE USE ONLY
Log No.
Permit No. 26154
Basin 092B

NOTICE OF INTENT NO. 52237

1. OWNER Space Era MHP
MAILING ADDRESS 4715 W. 4th St.
Reno, NV 89503

ADDRESS AT WELL LOCATION 145 W. Surge St. Reno, NV 89506

2. LOCATION SW 1/4 SW 1/4 Sec. 34 T 21N N/S R 19E E Washoe County
PERMIT NO. 26154 Issued by Water Resources
080-191-07 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 8" x 105' commercial well that had been in production. We removed the pump and perforated from approximately 85' to 15' from surface. We then pumped approximately 6 cu. yards of neat cement using tremie pipe from the bottom of the well to the top.				
Washoe Co. Permit # WL0400025				

Date started 7/28/2004, 19__
Date completed 8/2/2004, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 105 Feet Depth Cased 105 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	18	.188	0	105

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 85 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 105
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 36 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 8/3/2004

USE ADDITIONAL SHEETS IF NECESSARY

STATE ENGINEER
JAN 20 2011

FACSIMILE RCVD
Jan 20 2011 9:47AM BRUCE MACKAY PUMP WELL 775 851 1602 p.3