

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 112653  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34390

1. OWNER ACE CAB INC. ADDRESS AT WELL LOCATION 5010 S. VALLEY VIEW BLVD.  
MAILING ADDRESS 5010 S. VALLEY VIEW BLVD. LAS VEGAS NV.  
Subdivision Name: \_\_\_\_\_ County: CLARK

2. LOCATION NW 1/4 NW 1/4 Sec 29 T 21 N/S R 61 E Latitude 36° 55' 55" 42" N UTM E  NAD 27  
PERMIT/WAIVER No. 16229101043 Longitude 115° 12' 09" 5" W N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  New Well  Replace  Recondition  Deepen  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  Stock  Monitor  Municipal/Industrial  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ASPHALT</u>		<u>0</u>	<u>.25</u>	<u>.25</u>
<u>STONE SAND BASIS</u>		<u>.25</u>	<u>1.0</u>	<u>.75</u>
<u>SILTY BROWN CLAY</u>		<u>1.0</u>	<u>4.0</u>	<u>3.0</u>
<u>CLAY</u>		<u>4.0</u>	<u>10.0</u>	<u>6.0</u>
<u>SILTY BROWN SAND + CLAY</u>		<u>10.0</u>	<u>12.0</u>	<u>2.0</u>
<u>CLAY</u>		<u>12.0</u>	<u>18.0</u>	<u>6.0</u>
<u>SILTY BROWN SAND + SILT</u>		<u>18.0</u>	<u>21</u>	<u>3.0</u>
<u>CLAY</u>		<u>21</u>	<u>25</u>	<u>4.0</u>

9. WELL CONSTRUCTION

Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
<u>12</u> Inches	<u>0</u> Feet	<u>25</u> Feet	Feet
			Feet
			Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>SCH 40</u>	<u>0</u>	<u>25</u>

Perforations:

Type of perforation MACHINE SLOT  
Size of perforation .025

From 15 feet to 25 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout 1 to 10  Pumped  Poured  
 Concrete Grout 0 to 1  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 12 to 25  Pumped  Poured  
Type: NO#3

Bentonite Chips:  Yes  No 10 to 12  Pumped  Poured  
Type: 3/8"

Date started: 8-16, 20 10  
Date completed: 8-16, 20 10

7. Water Level  
Static water level: NONE feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

**DCNR/DWR RECEIVED**  
**SEP 10 2010**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EAGLE DRILLING Contractor  
Address 7150 PLACID ST. LAS VEGAS NV 89119 Contractor

Nevada contractor's license number issued by the State Contractor's Board 51266  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357

Signed Neil White  
By driller performing actual drilling on-site or contractor  
Date 9-2-2010