

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112851
Permit No. _____
Basin 220

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35587

1. OWNER Clazy H, LLC ADDRESS AT WELL LOCATION 2301 Glendale Blvd.
MAILING ADDRESS P.O. Box 70 Moapa, Nevada
Moapa, NV. 89025-0070 Subdivision Name Client Hole # RW4 County: Clark
2. LOCATION NE 1/4 NE 1/4 Sec 02 T 15 N R 66 E Latitude N. 36.665047 UTM E NAD 27
PERMIT/WAIVER No. 042-02-501-004 Longitude W. -114.568981 N NAD 83/WGS 84

3. WORKED PERFORMED New Well Replace Recondition
 Deepen Other
4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC Other HS Acifer

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy silt w/ gr.</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Sandy silt w/ clay</u>		<u>3</u>	<u>11</u>	<u>8</u>
<u>Gravelly silt w/ clay wet</u>		<u>11</u>	<u>16</u>	<u>5</u>
<u>Clay silt w/ small gravel</u>		<u>16</u>	<u>24</u>	<u>8</u>
<u>clay</u>		<u>24</u>	<u>28</u>	<u>4</u>
<u>Clay (Fat)</u>				

9. WELL CONSTRUCTION
Depth Drilled 28 Feet Depth Cased 28 Feet
HOLE DIAMETER (BIT SIZE)
From 12 Inches To 0 Feet
From 0 Inches To 28 Feet
From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>Sch 40 PVC</u>	<u>AST MF-480</u>	<u>0</u>	<u>28</u>

Perforations:
Type of perforation Factory Slots
Size of perforation .020
From 8 feet to 28 feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 7 to 28
Type: #12 Silica Sand
Bentonite Chips: Yes No 2 to 7 Pumped Poured
Type: 3/8 Bentonite Chips Hydrated Surface
to be completed by client as part of a water recovery system

7. Water Level
Static water level: 11 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc. Contractor
Address 4255 W. Post Rd. Contractor
Las Vegas, NV. 89118
Nevada contractor's license number 54931
issued by the State Contractor's Board
Nevada driller's license number issued by the M-1944
Division of Water Resources, the on-site driller
Signed Thomas M. Beal
By driller performing actual drilling on-site or contractor
Date 12/16/10

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>N/A</u>			