

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 12852  
Permit No. \_\_\_\_\_  
Basin 220

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35587

1. OWNER Clazy H LLC ADDRESS AT WELL LOCATION 2301 Glendale Blvd, Moapa, Nevada  
MAILING ADDRESS P.O. Box 70, Moapa, NV. 89025-0070 Subdivision Name: Client Hdr RW3 County: Clark  
2. LOCATION NE 1/4 NE 1/4 Sec 02 T 15 N R 66 E Latitude N. 36.664989 UTM E  NAD 27  
PERMIT/WAIVER No. 042-02-501004 Longitude W 114.569174 N  NAD 83/WGS 84

3. WORKED PERFORMED  New Well  Replace  Recondition  Deepen  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  Cable  Rotary  RVC  Other H.S. Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Si H w/organics</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Si H Sand w/ gravel</u>		<u>2</u>	<u>4</u>	<u>2</u>
<u>Silty Gravel w/clay</u>		<u>4</u>	<u>11</u>	<u>7</u>
<u>Sandy Si H w/ gravel w/ sm. Sand and Gravel layers</u>	<u>Wet</u>	<u>11</u>	<u>25</u>	<u>14</u>
<u>Clay w/ Tr. Sand</u>	<u>↓</u>	<u>25</u>	<u>28</u>	<u>3</u>

9. WELL CONSTRUCTION  
Depth Drilled 28 Feet Depth Cased 27 1/2 Feet  
HOLE DIAMETER (BIT SIZE)  
12 Inches From 0 Feet To 28 Feet  
Casing Schedule  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
4" sch 40 PVC ASTM F-48 0 27 1/2

Perforations:  
Type of perforation Factory Slots  
Size of perforation 020  
From 7 1/2 feet to 27 1/2 feet  
Annular Seal:  Neat Cement  Cement Grout  Concrete Grout  ≥30% Bentonite Grout  Yes  No  
to Pumped to Pumped to Pumped to Pumped  
Gravel Pack:  Yes  No 6 to 27 1/2  Pumped  Poured  
Type: #12 Silica Sand  
Bentonite Chips:  Yes  No 2 to 6  Pumped  Poured  
Type: 3/8 Bentonite Chips Hydrated

7. Water Level  
Static water level: 11 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Elite Drilling Inc. Contractor  
Address 4255 W. Post Rd. Las Vegas, NV. 89118 Contractor  
Nevada contractor's license number 54931  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources the on-site driller M-1944  
Signed Thomas H. Beall  
By driller performing actual drilling on-site or contractor  
Date 12/16/10

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>NA</u>		