

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 113017
 Permit No. 77497
 Basin 212

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35502

1. OWNER **Behnen Nicholas G**
 MAILING ADDRESS **1900 Silver Ave.**
LAS VEGAS, NV 89102

ADDRESS AT WELL LOCATION **1900 Silver Ave.**
LAS VEGAS, NV 89102

2. LOCATION **SE 1/4 NW 1/4 Sec 04 T 21 S R 61 E** **CLARK** County
 PERMIT NO. **77497** **162-04-210-119**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Irrigation Test
 Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
Aluvium		0	9	9
Caliche		9	12	3
Rock, gravel	x	12	13	1
Silty clay w/stringer of caliche		13	117	114
Gravel	x	117	120	3
Cemented w/stringers of sand		120	268	148
Gravel & sand	x	268	273	5
Cemented w/stringers of sand		268	350	72
WGS84				
36 09' 11.53"				
115 10' 04.04"				

8. WELL CONSTRUCTION
 Depth Drilled 350 Feet Depth Cased 337 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 350 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	sch40		+2	337

Perforations:
 Type perforation **Machine**
 Size perforation **.020**
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 337 feet

9. WATER LEVEL
 Static water level _____ 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 11/3, 20 10
 Date completed 11/5, 20 10

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>60-70</u>	<u>10-15</u>	<u>10-15</u>	

Name **ALLEN DRILLING INC**
 (CONTRACTOR)
 Address **4015 West Tompkins Ave.**
 (CONTRACTOR)
Las Vegas, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board **18916 & 18917**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2231**
 Signed Vitor Este
 By driller performing actual drilling on site or contractor
 Date **December 1, 2010**

36.153214°N NAD83
 115.166952°W D.D.
 RECEIVED
 DEC 10 2010

LAS VEGAS OFFICE

10 008 990

