STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113122
Permit No.
Basin 137B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65786 (1)

1. OWNER Round Mountain Gold M/O 2010-7
MAILING ADDRESS PO Box 480
Round Mountain, NV. 89405

ADDRESS AT WELL LOCATION Round Mountain Mine
Subdivision Name: County: Nye

2. LOCATION NW¼NW¼ Sec30T10N/ R44E
PERMIT/WAIVER NO. M/O-1647
Issued by Water Resources Parcel. No.

Latitude
Longitude
UTM E 492337 ☒ NAD 27
N 4283373 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other Plugging

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tan Quartz		0	390	390
Tan Rock		390	480	90
Grey Brown Mix		480	690	210
Grey Rock		690	1020	330

Transducer attached at 1000', 450', 350'. Pumped cement grout through the 2" casing to surface.Then inserted a tremmee pipe to create a 10' surface seal.
Hole is abandoned.

RECEIVED 2011 FEB 18 AM 10: 51 STATE ENGINEER'S OFFICE

Date started: January 25, 20 11
Date completed: January 27, 20 11

9. WELL CONSTRUCTION
Depth Drilled 1020 Feet Depth Cased 1000 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14.75 Inches	0 Feet	20 Feet
6.75 Inches	20 Feet	1020 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	5.02	.218	+2	1000

Perforations:
Type of perforation N/A
Size of perforation N/A
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	0 to 10	☒ Pumped	☐ Poured
☒ Cement Grout	10 to 1020	☒ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to	☐ Pumped	☐ Poured
Gravel Pack: ☐ Yes ☒ No	to	☐ Pumped	☐ Poured
Type:			
Bentonite Chips: ☐ Yes ☒ No	to	☐ Pumped	☐ Poured
Type:			

7. Water Level
Static water level: 856.95 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Warm °F
Quality: Fair

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8	N/A	1

38.7008160°N NAD27
117.088124°W

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2376
Signed
By driller performing actual drilling on site or contractor
Date February 15, 2011