

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113261
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20989

1. OWNER City of Las Vegas Public Works ADDRESS AT WELL LOCATION CLV Water Pollution Control Facility
MAILING ADDRESS 400 Stewart Avenue, Las Vegas, NV 89101 6005 East Vegas Valley Drive, Las Vegas, NV 89142

2. LOCATION SE 1/4 sw 10 T 21N NS R 62 E Latitude 36.132702 UTM E NAD 27
PERMIT/WAIVER No. DW-1113/A 161-10-401-004 Longitude -115.039122 N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____ Subdivision Name: _____ County: Clark

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other...
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty Sand (fill)		0	17	17
Gravel (fill)	x	17	27	10
Silty Sand (native)	x	27	50	23
MW-6				

I NEED TO INVESTIGATE THESE WELLS. PLEASE DON'T CHANGE ANYTHING ON THESE LOGS. THANKS, STEVE

DCNR/DWR RECEIVED
NOV 22 2010
LAS VEGAS OFFICE

8. WELL CONSTRUCTION

Depth Drilled	50	Feet	Depth Cased	50	Feet
---------------	----	------	-------------	----	------

HOLE DIAMETER (BIT SIZE)

From	To
18	0
Inches	Feet
	50
	Feet
	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch. 80	+1.9	20

Perforations:

Type of perforation saw cut
Size of perforation 0.02

From 20 feet to 50 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 10 Cement Grout
Placement Method: Pumped Poured Concrete Grout
Gravel Packed: Yes No
From 10 feet to 50 feet

9. WATER LEVEL

Static water level 17 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 68 °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kelley Dewatering and Construction Co.
Address 5175 Clay Avenue SW
Wyoming, MI 49548
Nevada contractor's license number issued by the State Contractor's Board 0050826
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2149
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 11-19-10

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Date started 3-Jun, 20 10
Date completed 3-Nov, 20 10