

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 113287  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35208

1. OWNER Douglas + ROSALINDA DEGRAZZIO ADDRESS AT WELL LOCATION SWANGER CIRCLE DR.  
MAILING ADDRESS 1701 HANDING AVE. ALTA FISH LAKE VALLEY NORTH SIDE LOT 17  
DENA CA 91001 Subdivision Name: WHITE MOUNTAIN UNIT 1 County: ESMERALDA

2. LOCATION NW 1/4 NW 1/4 Sec 22 T 4 N R 36 E Latitude 37° 34' - 894 UTM E  NAD 27  
PERMIT/WAIVER No. 007-631-02 Longitude 112° 58' - 311 N  NAD 83/WGS 84

3. WORKED PERFORMED  New Well  Replace  Recondition  
 Deepen  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SANDY LOAM</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>SAND</u>		<u>4</u>	<u>8</u>	<u>4</u>
<u>SAND + GRAVEL</u>		<u>8</u>	<u>173</u>	<u>165</u>
<u>ROCK + BOULDERS</u>		<u>173</u>	<u>182</u>	<u>9</u>
<u>SAND + GRAVEL</u>		<u>182</u>	<u>206</u>	<u>24</u>
<u>SANDY LOAM + CLAY</u>		<u>206</u>	<u>221</u>	<u>15</u>
<u>ROCK SAND + GRAVEL</u>		<u>221</u>	<u>320</u>	<u>99</u>

9. WELL CONSTRUCTION  
Depth Drilled 320 Feet Depth Cased 320 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 320  
Inches Feet  
Inches Feet  
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>	<u>16.74</u>	<u>.188</u>	<u>1</u>	<u>20</u>
<u>8 5/8</u>	<u>8.76</u>	<u>.508</u>	<u>SDR 17</u>	<u>320</u>

Perforations:  
Type of perforation SAW CUT  
Size of perforation 4" INCH BY 6" INCH 4 ROW  
From 320 feet to 220 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement 15 to SURFACE  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 320 to 50  Pumped  Poured  
Type: 3/8 PEA GRAVEL  
Bentonite Chips:  Yes  No 50 to 15  Pumped  Poured  
Type: 3/8 INCH BANO 10 HOLE PLUG

Date started: 7-26, 20 10  
Date completed: 7-31, 20 10

7. Water Level  
Static water level: 115 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: COOL °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>APP.</u>	<u>50</u>		<u>2 Hr.</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name BUDGET DRILLING CO Contractor  
Address P.O. BOX 3505 PARRAND NV Contractor  
89041  
Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 40020  
Nevada driller's license number issued by the \_\_\_\_\_  
Division of Water Resources, the on-site driller 1573  
Signed [Signature]  
By driller performing actual drilling on-site or contractor  
Date 8-10-2010