

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 113290
Permit No. _____
Basin _____

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 35519

1 OWNER Lyon William Homes Inc. ADDRESS AT WELL LOCATION 1640 E Rosada Way
MAILING ADDRESS 500 Pilot Road #G North Las Vegas, NV
Las Vegas, NV 89119-3624 Subdivision Name: _____ County: Clark

2 LOCATION NW ¼ SE ¼ Sec 35 T 19S N/S R 61 E Latitude N36 15' 173' UTM E _____ NAD 27
PERMIT/WAIVER No. 124-35-701-005 Longitude W115 07' 452' N _____ NAD 83/WGS 84
Issued by Water Resources Parcel No.

3 TYPE OF WELL is this well being plugged because a replacement well was drilled? No Is there an existing well log? Yes
 Domestic Irrigation Test Municipal/Industrial Monitor Stock If yes, what is replacement well NO? _____ If yes, what is NDWR well log #? 29639

4 EXISTING WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"				

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:
Type of perforation _____
Size of perforation _____
From _____ feet to _____ feet
From _____ feet to _____ feet

If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: Mills Knife
From 300 feet to 0 feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

5 WATER LEVEL
Static water level 50' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS
Material Used
From 300 feet to 0 feet 23 sack slurry Pumped Poured
From _____ feet to _____ feet Pumped Poured

6 Additional Notes or Comments

Neat Cement Fluid Weight _____ lbs/gal
Bentonite Grout _____ % bentonite
Date Started 1/26/2011
Date Completed 2/1/2011

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC Contractor
Address 4015 West Tompkins Ave. Contractor
Las Vegas, NV 89123
Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2388
Signed [Signature] By driller performing actual drilling on site or contractor
Date 2/11/2011

**DCNR/DWR
RECEIVED
FEB 22 2011**