

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32727

1. OWNER Greg Barlow ADDRESS AT WELL LOCATION Antelope Canyon
 MAILING ADDRESS PO Box 1005 Caliente NV
 2. LOCATION NE 1/4 SW 1/4 Sec 5 T 4 N 67 E Lincoln Lincoln - OK County
 PERMIT NO. 003-011-07 Issued by Water Resources Parcel No. _____ Subdivision Name ESPERANZA

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand - Boulders		0	55	55
Fractured Rock	X	55	86	31
Hard Rock		86	90	40

GPS UGS 84
 N 320 32.20
 W 1140 30.728

Waiver # OG-1000
 Dom permit # NV N1156
 API # 27-017-9001

DCNR/DWR
 RECEIVED
 OCT 07 2010
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 90 Feet Depth Cased 90 Feet
 HOLE DIAMETER (BIT SIZE)
1 5/8 Inches From 0 Feet To 90 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 1/2</u>		<u>.50</u>	<u>0</u>	<u>90</u>

Perforations:
 Type perforation Factory
 Size perforation 1 5/8 x 6 1/2
 From 51 feet to 80 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 51 feet to 90 feet

9. WATER LEVEL
 Static water level 41 feet below land surface
 Artesian flow 0 G.P.M. P.S.I.
 Water temperature 15.7 °F Quality poor

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling and pumps Contractor
 Address HC 61 Box 54 Hiko NV 89017 Contractor

Date started 9-20-2010, 20_____
 Date completed 9-29-2010, 20_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>		<u>2</u>

Nevada contractor's license number issued by the State Contractor's Board 0028266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 9-29-2010