STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113549
Permit No.
Basin 028

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66800

1. OWNER Hycroft/Allied mines
MAILING ADDRESS 9790 Gateway Dr Suite 200 Reno NV 89521

ADDRESS AT WELL LOCATION Hycroft mine 55 mi NW of Winnemucca, NV

2. LOCATION NE ¼ SE ¼ Sec 2 T 34 N S R 29 E
PERMIT/WAIVER No. M/0 1639 (Issued by Water Resources) 002-061-03 (Parcel No.)

Latitude 40.841864°N Longitude 118.687179°W
UTM E 357679.9 N 4522563.2 ☐ NAD 27 ☒ NAD 83/WGS 84
Subdivision Name: NAD 27 (TN) County: Humboldt

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Red/Bin oxidized volcanic alluvial grvl w/coarse quartz	/	0'	510	510'

RECEIVED 2011 APR -1 AM 10:12 STATE ENGINEER'S OFFICE

Date started 12-4, 2010
Date completed 12-13, 2010

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 510' Feet Depth Cased 507 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
16"	Inches	0'	Feet	20	Feet
8 3/4	Inches	20	Feet	~~427~~ 510	Feet
	Inches		Feet	~~427~~	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.75	32	.279	~~427~~ 0'	~~507~~ 20'
4.50	2.75	.337	~~427~~	~~507~~
			0'	427'

Perforations:
Type of perforation Slotted
Size of perforation 0.01
From 427' feet to ~~507~~ 507 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 410'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 410 feet to 510 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Stewart Bros Drlg Co (Contractor)
Address 306 Air Port Rd Milan, NM 87021 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 0026661
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1631
Signed Sheila McCord (By driller performing actual drilling on site or contractor)
Date 12-20-10

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY