WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 113738
Permit No.
Basin

NOTICE OF INTENT NO. 35449

1. OWNER AREA 51 ASSEMBLY INC
MAILING ADDRESS PO BOX 9351
PAHRUMP, NV 89060

ADDRESS AT WELL LOCATION 2421 W LARSEN DR

2. LOCATION SW 1/4 SE 1/4 Sec. 30 T 19 N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 29-523-09 (Parcel No.) TUMBLEWEED ESTATES (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	15	15
CALICHIE		15	25	5
CLAY		25	75	50
CALICHIE	WB	75	95	20
CLAY		95	120	25
CALICHIE	WB	120	128	8
CLAY		128	140	12
CALICHIE	WB	140	150	10
CLAY		150	165	15
CALICHIE		165	200	35
N36°15'55.7"				
W116°03'28.3"				

DEPARTMENT
RECEIVED
MAY 13 2011
LAS VEGAS OFFICE

Date started 4/30/2011, 19__
Date completed 4/30/2011, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12"	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.280	0	200

Perforations:
Type perforation SCREEN
Size perforation .032
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 5/2/2011

USE ADDITIONAL SHEETS IF NECESSARY