STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 113784
Permit No.
Basin 053

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66191

1. OWNER Guttry Family Trust
MAILING ADDRESS 3169 Midland Dr, Elko, NV 89801
ADDRESS AT WELL LOCATION Union Pass, Pine Valley
Subdivision Name: County: Eureka

2. LOCATION NE ¼ SE ¼ Sec 14 T 27N N/S R 52 E
PERMIT/WAIVER No. 0006-060-05 (Issued by Water Resources) Parcel No.
Latitude N 40* 13.181 Longitude W 116*04.016
UTM E N
[X] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC [X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	2	2
sand, gravel & boulders		2	12	10
granite		12	80	68
volcanic rock	X	80	110	30

40.219683°N NAD27
116.066933°W

Date started: 21-Sep, 20 10
Date completed: 25-Sep, 20 10

9. WELL CONSTRUCTION
Depth Drilled 110 Feet Depth Cased 110 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 3/4	Inches	0	Feet	110	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		.0188	+1	110

Perforations:
Type of perforation: mill slot
Size of perforation: 3/16 x 3
From 100 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 0 to 100 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 100 to 110 [ ] Pumped [X] Poured
Type: pea gravel
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 57 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200+		2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Alternative Drilling
Address (Contractor): P.O. Box 281166
Lamoille, NV 89828
Nevada contractor's license number issued by the State Contractor's Board: 73955
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1689
Signed (By driller performing actual drilling on site or contractor): [signature]
Date: 10-27-2010

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY