

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 113973  
 Permit No. \_\_\_\_\_  
 Basin 070

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66947  
66945

1. OWNER Gary & Maggie Everet ADDRESS AT WELL LOCATION 4625 Teal Lane  
 MAILING ADDRESS 16000 Highway 400 uniuionville NV Winnemucca, NV

2. LOCATION NE 1/4 SE 1/4 Sec 02T35N R37E Latitude 40°56.037 UTM E  NAD 27  
 PERMIT/WAIVER NO. N/A Parcel No. 013-035-01 Longitude 117°46.662 N  NAD 83/WGS 84  
*Issued by Water Resources*

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Monitor  Stock  
 Municipal/Industrial

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	2	2
Clay		2	50	48
Sand/fine gravel		50	90	40
Clay		90	95	5
Sand		95	110	15
Course Gravel	X	110	156	46
Sand		156	166	10
Course Gravel	X	166	200	34
Clay		200	218	18

9. WELL CONSTRUCTION

Depth Drilled 218 Feet Depth Cased 218 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10 5/8</u> Inches	<u>0</u> Feet <u>218</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>188</u>	<u>+1</u>	<u>18</u>
<u>6.625</u>	<u>4.06</u>	<u>.316</u>	<u>18</u>	<u>218</u>

Perforations:

Type of perforation Factory Cut Slots

Size of perforation 050

From 180 feet to 200 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement 0 to 50  Pumped  Poured

Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 55 to 218  Pumped  Poured

Type: \_\_\_\_\_

Bentonite Chips:  Yes  No 50 to 55  Pumped  Poured

Type: \_\_\_\_\_

Date started: April 26, 20 11  
 Date completed: April 29, 20 11

7. Water Level

Static water level: 61 feet below land surface

Artesian Flow: N/A G.P.M. N/A P.S.I

Water Temperature: Cool °F

Quality: Fair

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)
<u>15-20</u>			<u>4.5</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fred Anderson Drilling, Inc. (CONTRACTOR)

Address 10760 S. Grass Valley Road (CONTRACTOR)  
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 021467

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083

Signed Fred Anderson Drilling, Inc.  
 By driller performing actual drilling on site of contractor

Date May 26, 2011