COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 114088
Permit No.
Basin 212

NOTICE OF INTENT NO. 35533

1. OWNER CLARK COUNTY WATER RECLAMATION
MAILING ADDRESS 5857 E. FLAMINGO RD.
LAS VEGAS, NV 89122

ADDRESS AT WELL LOCATION CCWRD #643
Tropicana & Eastern Ave. (Public right away)

2. LOCATION NW ¼ NW ¼ Sec 25 T 21 S R 61 E CLARK County

PERMIT NO. DW1309 (Issued by Water Resources) | 162-25-199-010 (Parcel No.) | Dewater - DBB (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1-40' Dewater well				
Asphalt		0	6"	6"
Type II		6"	2'	18"
Silty Clay		2'	10'	8'
Silty clay & rock		10'	18'	8'
Silty clay & rock	xx	18'	19'	1'
Clay - brown		19'	40'	21"
WSG84				
N36 05' 59.39"				
W115 07' 07.77"				

DCNR/DWR
RECEIVED
MAY 24 2011
LAS VEGAS OFFICE

Date started 5/2, 20 11
Date completed 5/4, 20 11

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
24 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	.0250	0	40

Perforations:
Type perforation Machine
Size perforation 1/4"x2.5"x21 per ft.
From 20 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No Seal Type:
Depth of Seal ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow no G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 0018916 & 0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161-David Strouse
Signed
By driller performing actual drilling on site or contractor
Date May 19, 2011