

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 114125
Permit No. 69128
Basin 162

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35456

1. OWNER SHAPIRO DAVID + ILANA

MAILING ADDRESS 301 E DELMAR DR
HENDERSON, NV 89015-8105

ADDRESS AT WELL LOCATION 3971 E KELLOG RD

2. LOCATION NE 1/4 NE 1/4 Sec. 19 T 21

N/S R 54 E NYE County

PERMIT NO. 69128
Issued by Water Resources

45-271-33
Parcel No.

GREEN SADDLE RANCH
Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. COM. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		140	210	70
CALICHIE		210	270	60
LIMESTONE		270	300	30

COMMERCIAL WELL

N36°07'01.1"

W115°56'25.6"

8. WELL CONSTRUCTION

Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>7-7/8</u> Inches	<u>140</u> Feet	<u>300</u> Feet
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>2.37</u>	<u>.248</u>	<u>0</u>	<u>300</u>

Perforations:

Type perforation FACTORY SAW

Size perforation .032

From <u>200</u> feet to <u>300</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No

Depth of Seal _____

Placement Method: Pumped

Poured

Seal Type:

Neat Cement

Cement Grout

Concrete Grout

Gravel Packed: Yes No

From _____ feet to _____ feet

9. WATER LEVEL

Static water level 75 feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.

Contractor

Address P.O. BOX 4220

Contractor

PAHRUMP, NV. 89048

Nevada contractor's license number issued by the State Contractor's Board 47333

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed [Signature]
By driller performing actual drilling on-site or contractor

Date 6/14/2011

Date started 6/13/2011, 19

Date completed 6/14/2011, 19

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M. Draw Down (Feet Below Static) Time (Hours)

DCNR/DWR
RECEIVED

JUN 16 2011

LAS VEGAS OFFICE